

ADDENDUM NO. 1  
TO  
CITY OF PINEHURST, TEXAS

June 2, 2025

TROPICAL STORM IMELDA  
CDBG-DR CONTRACT NO. 24-067-012-E199  
SEWER FACILITIES (Lift Stations)  
PROJECT No. 1

THIS ADDENDUM IS ISSUED FOR THE PURPOSE OF AMENDING THE CONTRACT DOCUMENTS AND PLANS FOR THE ABOVE PROJECT FOR THE CITY OF PINEHURST, TEXAS.

The following additions, deletions, modifications, or clarifications shall be made to the appropriate sections of the plans and specifications and shall become part of the Contract Documents.

When submitting bid, Bidders **MUST** acknowledge receipt of this Addendum No. 1 on the appropriate page within the bid proposal.

**CONTRACT DOCUMENTS:**

**Wage Rate Decision.** The wage rate is hereby replaced in its entirety. See attached.

**CIVCAST QUESTIONS:**

Q1. Is there an estimated cost?

A1. The estimate for this project is \$793,000.00

Q2. I cannot find the dimensions of the new grinder lift station for Warbler Street. Is there a basin dimension / detail sheet?

A2. The diameter of the wet well is 4 feet, see sheet 8 of 13.

END ADDENDUM No. 1



  
\_\_\_\_\_  
Stephen J. Jordan, P.E.